



NOTES :

- 1 : The Valve Top Except Face Of The Flange And Inst. Outlet Shall Be Painted Fire Red Of Shade No. 536 Of IS: 5. The Outside Of Instantaneous Outlet Shall Be Highly Polished The Hand Wheel Shall Be Painted Black Paints Shall Confirm To IS: 2932.
- 2 : Water Tightness Test For The Valve : 18 KGF/CM2. (For 2.5 Min.)
- 3 : Hydrostatic Pressure Test : 23 KGF/CM2. (For 2.5 Min.)
- 4 : Flow Test : 900 LPM Min. @ 7 KGF/CM2. (For Single Outlet)

| | | | | | |
|------------------|---------------------|----------------------|------------------|--------------------|----------------------|
| 1 | Body | SS 304 IS: 3444 Gr.1 | 12 | Hand Wheel | C.I IS: 210 |
| 2 | Spindle | SS 304 | 13 | Female Outlet | SS 304 IS: 3444 Gr.1 |
| 3 | Bonnet | SS 304 IS: 3444 Gr.1 | 14 | Lower Lug | SS 304 IS: 3444 Gr.1 |
| 4 | Gland Bush | SS 304 IS: 3444 Gr.1 | 15 | Upper Lug | SS 304 IS: 3444 Gr.1 |
| 5 | Gland Packing | Asbestose Rope | 16 | Blank Cap | ABS |
| 6 | Gland Nut | SS 304 IS: 3444 Gr.1 | 17 | Rubber Ring | Rubber IS: 937 |
| 7 | Check Nut (Spindle) | SS 304 IS: 3444 Gr.1 | 18 | Cam Tooth | SS 304 IS: 3444 Gr.1 |
| 8 | Seat Washer | Rubber IS: 937 | 19 | Spring | IS: 6528 |
| 9 | Stop Valve | SS 304 IS: 3444 Gr.1 | 20 | Chain | Galvanized |
| 10 | Seat Check Nut | SS 304 IS: 3444 Gr.1 | 21 | Flange | M.S IS: 2062 |
| 11 | Hex. Nut | M.s | 22 | Pipe | IS: 1239 Heavy Gr. |
| NO. | DESCRIPTION | MATERIAL | NO. | DESCRIPTION | MATERIAL |
| PART LIST | | | PART LIST | | |



Shah Bhogilal Jethalal & Bros.

AHMEDABAD

TITLE :

Hydrant Stand Post, Single Outlet,
75 mm, Mild (Carbon) Steel

SCALE

N.T.S

DRAWING NO:

M193-75BJ

SHEET

1 OF 1

REV.

0